

PRE QUALIFYING REQUIREMENTS

These pre qualifying requirements (PQR) shall prevail over the pre qualifying conditions mentioned in “Instructions to Tenderers” or anywhere in the tender documents.

PRE-QUALIFYING REQUIREMENTS FOR REGULAR SUPPLIER.

1. Manufacturer :-

The firm shall themselves be manufacturer of 11 KV VCB Indoor Switchgear Panels.

2. Turn Over :-

The Bidder should have a minimum average annual turnover (MAAT) of Rs. 25 Crores per annum for best three financial years out of last five financial years. The audited balance sheet/CA's certificate with UDIN number shall be enclosed in support of above, failing which the bid shall not be considered.

3. Operational Experiences:-

The firm must have supplied the 11 KV Indoor VCB Panels to government/government undertaking/ power utilities directly or through EPC contractor and should have given three year proven trouble free operational service in tropical climate prevailing in India.

4. Manufacturing experience:-

The indigenous manufacturer must have manufactured at least. 50% of the total tendered quantities of 11 KV VCB Panels during last seven calendar years. The manufacturing experience of only last five Calendars Years (**Year 2016, Year 2017, Year 2018, Year 2019 & year 2020**) shall be considered for eligibility of tenderer. The firm shall have to submit the details of manufacturing of 11 KV VCB Panel during last five Calendars Years in following proforma:-

Table- PE

| Year | Complete postal address including designation of authority placing order | Order no. & date (for all ratings) | Quantity Ordered (Nos.) | quantity supplied during the year (Nos.) | Balance quantity to be supplied against orders in hands (Nos.) |
|--------------------|--|-------------------------------------|-------------------------|--|--|
| 1 | 2 | 3 | 4 | 5 | 6 |
| Calendar Year 2016 | | | | | |
| Calendar Year 2017 | | | | | |
| Calendar Year 2018 | | | | | |
| Calendar Year 2019 | | | | | |
| Calendar Year 2020 | | | | | |

The tenderer shall have to submit self attested copies of purchase orders & despatch instructions to substantiate the above details failing which their bid shall not be considered. If tenderer does not submit the proforma & only encloses the copies of purchase orders & despatch instructions, then their bid may not be considered.

5. Minimum quantity to be quoted :- 100% of the tendered quantity of 11 KV VCB.

6. Testing Facilities:-

The tenderer must have all necessary facilities at their works for carrying out such routine and acceptance tests as prescribed in the relevant ISS and any other routine and acceptance test as specified in the specification. Documentary evidence of existence of such facilities will be filed along with the tender.

7. Type Test:-

The firm should have valid type test reports of the offered VCB as per GTP /Technical specification during the last 5-year period from CPRI/ERDA. An undertaking for type test report shall not be acceptable.

All statements and claims regarding turnover, operational and manufacturing experience should be duly supported by authenticated copies of documents without which the tender is liable to be rejected summarily. PVVNL may call the tenderer to produce original purchase order/dispatch instruction or any other document for verification of submitted documents during the evaluation of their bid. The bidder is also required to submit an affidavit on stamp paper regarding the firm not being blacklisted by any government utility anywhere in India. If any information provided by the bidder is found to be concealed, supersede or incorrect at the later date, may lead to not only the cancellation of purchase order, if placed by on the tenderer, along with imposition of financial penalty and business debarment.

Note: - PVVNL reserves the right to waive minor deviation if they do not materially affect the capability of the applicant to perform the contract.