

**CONSUMER COPY**

**Joint Checking Report of CT/CT-PT Operated Meter (MT-1 Proforma)  
M&P Division, UHBVN, Ambala**

B/F Page \_\_\_\_\_ CIN No \_\_\_\_\_ C/F on Page \_\_\_\_\_

1. Purpose of Checking <b>Resealing New</b>	9. Date of Present Check <b>04-04-2016</b>
2. Name of Consumer <b>Executive EDD-ONE BIRKATAPRI</b>	10. Date of Previous Check _____
3. Account No. <b>LS-11</b>	11. Meter Make & Sr. No. <b>11PL 573812</b>
4. Name of Divn. <b>Yamuna Nagar</b>	12. Meter Branch No. _____
5. Name of S/Divn <b>NO I.</b>	13. Meter CT Ratio <b>15A.</b>
6. Sanctioned Load <b>600kw.</b>	14. Meter PT Ratio <b>11kv/110V.</b>
7. Contract Demand <b>---</b>	15. CT Ratio Installed <b>50/5A</b>
8. (a) Non Seasonal <input checked="" type="checkbox"/>	16. PT Ratio Installed <b>11kv/110V.</b> <b>Combi unit.</b>
(b) Seasonal (S/W) _____	17. Revs/Pulse per KWH <b>= 160.</b>
(c) Type of Industry <b>Village (U.P. State)</b>	18. Meter MF _____

19. Actual M/F (In figures as well as in words) = **R x 10**

Reading	PF	AC-tod	Tampers on Display of Meter
T.R. Time <b>11-4-16</b>	<b>0.85</b>		<b>Tc = 36</b>
n (MD reset count) <b>007</b>	<b>1.25</b>	1) <b>610.7</b>	
U (Kwh-Import) <b>1421.2</b>		2) <b>137.9</b>	
u (Exmport-Kwh) <b>---</b>		3) <b>443.6</b>	
r (KVArh -Lag) <b>935.1</b>		4) <b>5.0</b>	
r (KVArh -Lead) <b>1.7</b>		5) <b>49.3</b>	
A (KVAh) <b>1805.5</b>		6) <b>64.5</b>	
C (Cum Demand) KVA <b>4754</b>		7) <b>7314.9</b>	
H (Power on hours) <b>7795.18</b>		8) <b>147.8</b>	
d 1 (nd-tod MD in KVA) <b>4.58</b>			

21. Position of seals	Before Checking	After Checking
a) M&P	<b>E15220501, E15220502</b>	<b>E1259018, E1259019</b>
b) S	<b>---</b>	<b>---</b>
c) MD	<b>---</b>	<b>E1259017</b>
d) TC	<b>---</b>	<b>E1259015, E1259016</b>
e) CT/PT	<b>(E1529016, E1529017, E1529018) / Seal</b>	<b>Existing + E1259019, 2012</b>
f) COMPANY SEAL	<b>1000183, 1000184</b>	<b>Existing</b>
g) METER COVER	<b>F1068073, F1068074</b>	<b>do</b>

**OBSERVATIONS** - Visited as per SDO op' Endst No. 766/JE dated 04-04-2016 to check and re-seal the already released connection by SDO op' & installed are not of proper capacity as per sanctioned load.

- Accuracy of meter checked and found within limits.
- C-T/PT Combi unit to be installed before C.O-switching wiring to be through C.T pipe
- Proper capacity as per S-load to be provided. Meter to be provided M.F. R x 10 (Ten). Copy of C&E approval to be supplied to M&P office.
- Good survey taken in CRM.

Signature of consumer of his representative in token of acceptance of results and receipt of copy  
 Endst no. Ch..... /CT.....  
 Signature of SDO (OP) \_\_\_\_\_  
 Signature of JE (M&P) \_\_\_\_\_  
 Signature of SDO (M&P) \_\_\_\_\_  
 Dated.....  
 Copy of this report forwarded to the following for the information (as per section) action please  
 1) SDO/JE (OP) UHBVN  
 2) XEN (OP) UHBVN  
 3) SE (Op) UHBVN, / KKR/Ambala/Kaithal/Yamunanagar  
 4) SE (M&P) UHBVN, Panchkula  
 5) CA, UHBVN, Panchkula  
 6) RA C/O (Op) S/Divn/UHBVN

**XEN, (M&P) Divn.  
UHBVN, Ambala**

Handwritten signature and stamp: **फिरो (राओ) मंत्रालय/विद्युत विभाग**



MTI No 45727

CONSUMER COPY

Joint Checking Report of CT/CT-PT Operated Meter (MT-1 Proforma)  
M&P Division, UHBVN, Ambala

B/F Page

CIN No

C/F on Page

1. Purpose of Checking <i>Resealing New</i>	9. Date of Present Check <i>04-04-2016.</i>
2. Name of Consumer <i>Executive EDD-ONE DIKKA TAPRI. (MAIN)</i>	10. Date of Previous Check
3. Account No. <i>LS-11.</i>	11. Meter Make & Sr. No. <i>HPL 573817.</i>
4. Name of Divn. <i>Yamuna Nagar</i>	12. Meter Branch No. <i>DKTS</i>
5. Name of S/Divn <i>NIUI</i>	13. Meter CT Ratio <i>1SA</i>
6. Sanctioned Load <i>600kw.</i>	14. Meter PT Ratio <i>11kv/110V</i>
7. Contract Demand	15. CT Ratio Installed <i>3x 20/5</i>
8. (a) Non Seasonal <input checked="" type="checkbox"/>	16. PT Ratio Installed <i>11kv/110</i>
(b) Seasonal (S/W)	17. Revs/Pulse per KWH
(c) Type of Industry <i>...</i>	18. Meter MF

Actual M/F (In figures as well as in words) =  $R \times 4$  (four).

20. Reading	PF	AC-tod	Tampers on Display of Meter
<i>4.4.16.</i>			
Time <i>1346</i>	<i>0.00</i>		
n (MD reset count) <i>007.</i>		1) <i>20.8</i>	/
U (Kwh-Import) <i>72.0</i>		2) <i>4.2</i>	
u (Exmpor-Kwh)		3) <i>41.1</i>	
r (KVAh -Lag) <i>76.1</i>		4) <i>1.4</i>	
r (KVAh -Lead) <i>2.2</i>		5) <i>2.2</i>	
A (KVAh) <i>83.2</i>		6) <i>2.9</i>	
C (Cum Demand) KVA <i>51.00.</i>		7) <i>11.0</i>	
H (Power on hours) <i>7794.21</i>		8) <i>4.6</i>	
d 1 (nd-tod MD in KVA) <i>0.14.</i>			

21. Postition of seals	Before Checking	After Checking
a) PCB <i>F193387</i>	<i>F193388.</i>	<i>E1259007, 9008, 9009.</i>
b) OP		<i>E1259010.</i>
c) TB		<i>E1259002, E1259003.</i>
d) MDI		<i>E1259006.</i>
e) TC		<i>E1259004, E1259005.</i>
f) CT/PT <i>E1523403</i>	<i>E1523404.</i>	<i>E1259700, E1259001.</i>
g) COMPANY SEAL <i>7900169</i>	<i>7900170.</i>	<i>-Existing-</i>
h) METER COVER <i>F1068084</i>	<i>F1068083</i>	<i>-</i>

**OBSERVATIONS**  
 - Visited as per SDO op' ends No. 766/J.E dated 04-04-2016.  
 to check and re-seal the already released connection by SDO op.  
 C.T. not installed as per Sanctioned load to avoid loss of revenue connection checked.  
 - Accuracy of meter checked and found Dead stop as TTB screw found closed, same got opened accuracy after setting right checked and found within limits.  
 - Proper capacity C.T. as per S.I. to be provided. Modern to be provided.  
 - M.F.  $R \times 4$  (four) MCB to be granted properly. C.E.S approval copy to be supplied to M&P office. Load survey to be done.

Signature of consumer of his representative in token of acceptance of results and receipt of copy  
 Signature of SDO (OP) *[Signature]*  
 Signature of JE (M&P) *[Signature]*  
 Signature of SDO (M&P) *[Signature]*  
 Endst no. Ch..... ICT.....  
 Copy of this report forwarded to the following for the information & necessary action please  
 1) SDO/JE (OP) UHBVN  
 2) XEN (OP) UHBVN  
 3) SE (Op) UHBVN, / KKR/Ambala/Kalthal/Yamunanagar  
 4) SE (M&P) UHBVN, Panchkula  
 5) C.A. UHBVN, Panchkula  
 6) RA C/O (Op) S/Divn/UHBVN

*[Signature]*  
 नियो (ताओ)  
 नियोनियोनियो. मेत्र





ॐ

-2-

LAMPS FANS PLUGS		Appliances, Heaters, Cookers Refrigerators, etc.		Motors	
1		2		3	
Description	Wattage	Total	Description	Wattage	Total No.
B.P.F.	Total				each
each	Each				

The plug points for lamps, fans, etc. to be shown under col. 1 and those for appliances under col. 2

Total connected load of the above installation watts/kilowatts.

Declared Contract Demand

KVA

Signature of applicant

Present address

Signature & address of witness

*[Signature]*  
Executive Engineer  
Electricity Distribution Division-I  
Saharanpur

*[Signature]*  
AEE '00' S/DIV. No 1 YNR

*[Signature]*  
नो (वा०)  
पाविवाविनिावि० मेरठ





## M.C.G.

1. \_\_\_\_\_ (hereinafter referred to as the consumer shall when the contract so permits, also include my successors and assigns) hereby agree to take supply from the UTTARI HARYANA BIJLI VITRAN NIGAM LTD. (hereinafter called the supplier for a period of \_\_\_\_\_ year commencing from the date of suppliers readiness to give supply.
2. The consumer shall pay to the supplier a minimum charges of Rs. \_\_\_\_\_ per annum excluding service rental in case the less the this amount and this shall be adjusted annually.
3. Provided that if the total revenue on account of cost of energy only(excluding services rentals, meters, meter hire and Sundry charges) amounts to the total amount of MCG calculated for \_\_\_\_\_ Years, i.e. Rs. \_\_\_\_\_ earlier than \_\_\_\_\_ Years, the charging of Minimum consumption guarantee from the consumer shall cease for forthwith but the consumer shall continue to pay service and general charges, prescribed by the consumer, so long as the continues to take the energy thereafter.
4. Provided further that the supplier may, at his discretion, waive off the recover of minimum charges mentioned above during the period or period in which any restriction are imposed by him on the Supply of energy of the consumers. In such case the period of \_\_\_\_\_ years of MCG will not be reckoned from the date of suppliers readiness to give supply but will be calculated supply has been made available by the suppliers to the consumer. The total terms of agreement in such a case will be extended by the period or periods which supply is made to the consumer on restricted hours basis.
5. In the event of the consumer discontinuing to take supply before the expiry of the period of \_\_\_\_\_ years mentioned in clause I above or being disconnected by the suppliers for any breach of the conditions of supply on the part of the consumer he shall in addition to paying all arrears up to the date discontinuance, either continues to pay the supplier firm the date onwards till the expiry of the said period of \_\_\_\_\_ years a sum or sums as the case may be calculated at the said minimum charge of Rs. \_\_\_\_\_ per annum service penal as per Suppliers a Schedule of service charges referred to above or may if he so chooses, in view physical revenue from the sale of power only paid up to the date of discontinuance plus the service rental from the date of discontinuance up the expiry of the period of \_\_\_\_\_ years.
6. Subject to the above the recovery of minimum charges mentioned in clauses 2 and the services rental mentioned in clauses shall commence from the date as described in clause 1 above irrespective of the fact whether the consumer actually starts taking supply from the date of not.

WITNESSES :

1  
2

  
AEE (OP) S/DIV. 1 YNR

  
Executive Engineer  
Signature of the consumer  
Electricity Distribution Division-1  
Saharanpur

नियो (रातो)  
गणविनिनिनिनि मेर



ॐ

**UNDERTAKING**

I hereby agree that the Uttar Haryana Bijli Vitran Nigam shall have the right to restrict the hours of supply to my installation as and when required and I may be suspended to on that account. I further agree that if I am premises for a week and the offence. If repeated installation connection will be disconnection for a month will not be connected till the receipt of orders from the sanctioned authority.

2. That I will purchase \_\_\_\_\_ BHP motor when my load is approved by the competent authority.
3. That I have read the tariff and agree to it.
4. That I will pay the monthly rent whichever is imposed upon me by the contracting authority.
5. That I will stand M.C.G.
6. That the land to be irrigated is \_\_\_\_\_ acres.
7. That the building will be constructed seen at the consent of sanctioned.
8. That I am very much serious to get the connection at the earliest.
9. That I also agree to take connection on the right hour basis and will not run motor during day hours.

**WITNESSES:-**

1

2

Signature of the consumer  
 AEE '00' S/D/O No. 1 YNR.

Signature of the consumer  
 Executive Engineer  
 Electricity Distribution Division-1  
 Saharanpur

नि० (प०)  
 प० वि० वि० नि० लि०, मेरठ



ॐ

### UTTAR HARYANA BIJLI VITRAN NIGAM NOTIFICATION

In exercise of the powers conferred by Section 49 of the Electricity Supply Act, 1948 (Central act, 54 of 1948 and in exercise of all others powers under that act or under other law of the time being force enable it to set in this behalf the Uttar Haryana Bijli Virtran Nigam hereby makes the following further amendments to the terms and conditions of supply relating to the supply of Electricity.

In the said terms and conditions of supply relating to the supply of electricity

1. For condition 24 A, the following condition shall be substituted namely:-

24. A liability for prejudicial use of the supply. Malpractice or theft a consumer shall be liable for the various penalties hereby mentioned, without prejudice to his liability for prosecution for any offence constituted by that act.

#### Prejudicial Use of Supply

A consumer shall be quality of an act of prejudicial use of supply:

a) Where he keeps connected to the Nigam supply system any apparatus of adopts any electrical appliance. Other than the normal appliances for which he was given a connection and is likely to effect injuriously the supply of energy to other consumer or

Executive Engineer  
Electricity Distribution Division-1  
Saharanpur

नि० (वा०)  
य०वि०वि०नि०लि०, मेरठ



ॐ


### CLAUSE 14 OF TERMS & CONDITIONS SUPPLY

METERS: A correct meter shall be installed maintained by the Nigam at the each of supply of the premises of the consumer and shall be remain the property of the Nigam. The Nigam reserve to fix the position of the said meter.

b) The consumer may if he is so elects, cause his owner (meter) duly tested at the Nigam's laboratory or tested by Electrical inspector to be installed, which will be sealed by the board.

c) Should the consumer enquire the said meter to be removal of its position charged he shall give notice to that effect in writing to the Nigam and the Nigam shall Comply with such notice subject to the consumer paying the charges prescribed in schedule of general in advance.

d) Should the consumer dispute the accuracy of the said meter he may upon giving notice in writing to the Nigam and paying in advance the prescribed fee mentioned in schedule of general charges cause a test of the meter to be made by the Nigam. and if no such test of the meter to be made by the Nigam and if no such refund charges as such shall adjust the consumer account as may be required with respective affect for a period not exceeding 6 month immediately proceeding the date of such a prescribed by the rules under the act. The amount paid by the consumer for test will stand forfeited.

  
Executive Engineer  
Electricity Distribution Division

Contd..2.. 


नि (वा०)  
पाविनि० लि०, मेरठ

-2-


e) Should, the Nigam at any time defect the meter at a consumer's premises to be out of order incorrect the Nigam shall cause a test of the said meter carried out and should the meter carried and should the meter provide to be not correct, the consumer account will be adjusted, described above in sub clauses(s) if however the meter happen to be consumer own property, the consumer will pay to the Board the expenses of the test.

f) Subject to the provisions of sub clauses (s) (f) above the supply taken by the consumer as mentioned by the said meter shall be deemed to be correct and binding on consumer.

g) Should the Nigam any time detect the meter at consumer premises to be incorporated (if the consumers informed the Nigam it will be replaced with a accurate meter The electricity supplied to be consumer during the period in which the said meters had ceased to the consumer to the function shall be determined b taking average consumption of the last three months or six months proceedings the period which switch the be ceased to function whichever to be comparable. Provided that if the said meter ceased to function within the first three months of the meters by a correct meter shall be taken.

  
 Executive Engineer  
 Electricity Distribution Division-1  
 Saharanpur  
 Signature of the applicant.



  
 नो. (वा०)  
 पाठविनिर्माण, मेरठ



ANNEXURE-A

AMENDMENT OF CLAUSE -29

Expecting the cases of theft/ pilferage, every other dispute, difference, question, matter or claim, arising out of IE concerning or relating to the supply of electricity between the Nigam and the consumer shall be referred to the sole arbitration of C.E. (arbitration) of the Nigam or his nominee not below the rank of the S.E. the decision of the Nigam, provision of the Arbitration Act, 1940 (Act X of 1940) and the rules thereunder shall to any such reference. Provided that reference to Arbitration shall be resorted to only after remedies available in clause

24-a ibid have been exhausted.

This is without prejudice to the right to the Nigam recovery of the arrears or dues ( Disputed or otherwise) under the Haryana Govt. electrical undertaking (Dues Recovery Act, 1970)

WITNESS :-

- 1
- 2

Signature of the consumer.

*[Handwritten Signature]*  
 Executive Engineer  
 Electricity Distribution Division-I  
 Saharanpur

*[Handwritten Signature]*  
 नि० (वि०)  
 टावि०वि०नि०लि०. मेरठ

*[Handwritten Signature]*  
 17/11/2017

ॐ

### CLAUSE 10 OF TERMS AND CONDITIONS OF SUPPLY EXTENSION TO CONSUMER INSTALLATION

That consumer's install actual shall consist of energy consuming apart (i.e. motors, fans etc.) to the Nigam system wiring of any change being made in writing and the notice must be accompanied by a wiring contractors test report in the prescribed form No. without prior approval of the board in writing obtained after submitting in application with the prescribed form.

- b) In the event of any unauthorized extension having been made to the installation or any increase in maximum demand to the Nigam shall be entitled to disconnect the consumer premises from system of any raised extension the consumer shall pay to the Nigam all expenses on account of and connection with such damage damages determined by Nigam.
- c) If any supply consumer exceeds is declared contract demand by more than 5% liable to pay surcharge of 25% on the bill of S.O.P. relating to that month without prejudice to the right the Nigam may also recover the damages charges for all account and may also cause the service of the consumer to be disconnected.
- d) If any consumer taking Industrial supply changes his industry even through his connected load remained the same he will intimate such in the Nigam.

Witnesses & surety for payment

- 1.
- 2.

Signature of consumer  
Executive Engineer

Electricity Distribution Division-1  
Bhubaneswar

नि (वा०)  
पोविनि०लि०, मेरठ



ॐ

8 Writing Condition:-

a) The writing and apparatus comprising the consumers installation must always be in good order condition, so as not to effect injuriously UTTAR BIJLI VITRAN NIGAM LTD. WORKS or the use of energy by other consumer.

b)The writing shall conform with the rule of the particular Fire Insurance company in which the building or the consumer's premises may be insured, ( if this is insured) and with such writing regulation of the UTTAR BIJLI VITRAN NIGAM LTD. as be in force from time to time.

c) Till such time the UTTAR BIJLI VITRAN NIGAM LTD. frames its own writing rules on the institution of Electrical Engineers and the specification for electrical works in Govt. Building in the Haryana issued by the Haryana Govt. and also those specified in Indian standard " cord of practice for electrical writing & fitting and building issued by Indian standards institutes are recommended for adoption.


d) The consumer must in all cases

+ provide linked quick break main switches and a main fuse on each pole other than the earthed natural which must be place within three feet of Nigam meter on in such other position as shall be approved by the UTTAR BIJLI VITRAN NIGM LTD.

E) Motors of rated capacity not exceeding 4 KW may be started direct from the consumer main by means of linked poled switches , but all motors of greater rated capacity must by provided with starting resistance, auto transformer, star delta

Cond 2.....

Executive Engineer  
Electricity Distribution Division-I  
Saharanpur

  
नि० (बा०)  
10वि०वि०नि०लि०, मेरठ

  
10वि०वि०नि०लि०, मेरठ

ॐ

-2-

switches, or other kind of starting gear to be approved by the UTTAR BIJLI VITRAN NIGAM LTD. All motors of a rated capacity exceeding 4 KW must be provided by the consumer with over load and no volt and no release gear which must all times be maintained in perfect working order.


g) Motors of a rated capacity exceeding 4 KW but not exceeding 50 KW may be of squirrel cage type but the starting device shall be designed to keep the starting correct within twice the full load current.

h) Where wiring for motors is in conduct all phase wires must be run bunched in a single metallic conduct which must be efficiency earthed throughout and connected to the frame of the frame of the motors. The earth wire must not be smaller than the equivalent of no. & S.W.G. copper.

i) No electrical installation work (including additions, alteration, repairs, adjustment to existing installation) except such replacement of lamp, fans, fuses, switches, low voltage domestic appliances and fitting as in no way alter the capacity and character of installation shall be carried out upon the premises on behalf of any consumer or owner except by an electric contractor by Chief Electrical Inspector and under the direct supervision of a person holding certificate of competency issued by the inspector.

  
Signature of the applicant.

Executive Engineer  
Electricity Distribution Division-1  
Saharanpur

  
नो (वा०)  
उ०वि०वि०नि०लि०, मेरठ

  
AEE 105/500/1/1/1/1



AFFIDAVIT

I, \_\_\_\_\_  
resident of \_\_\_\_\_

do hereby solemnly affirm and declare as under:-

1. That I hereby apply for H.T. Industrial Connection for my factory through Urban Power Supply by providing an independent smooth running of my factory.

The I/we have applied for a DB/ND8/RCU/CUN/Power Connection Extension of Load/Reduction of load with U.H.B.V.N. for my House/Shop.

3. That I shall abide by the rules and regulations amended from time to time by U.H.B.V.N.

4. That I/we will ensure power factor of 0.90 by installing shunt capacitor of ISI mark, otherwise penalty as per rules may be imposed.

5. That I/we will have no claim on release of connection till such time the infrastructures is completed.


6. That I/we are not defaulter of any charges whether disputed or undisputed.


7. That I/we will not raise any claims against the department for unnotified/unscheduled power cuts which are beyond the control of the department.


VERIFICATION

Verified that the contents of the above affidavit are true and correct to the best of my knowledge and belief and nothing has been concealed therein.

Verified at Jagadhri  
on \_\_\_\_\_

  
Executive Engineer  
Electricity Distribution Division-1  
Sabaranpur

  
Department  
Executive Engineer  
Electricity Distribution Division-1  
Sabaranpur

  
नियो (नं०)  
प्राविधिकनिलि, मेरठ

### UNDERTAKING FOR BUILDING UP LOAD

I/we undertake to make up the load to the extend of the load sanctioned within a period of six months from the date of connection failing which on the event of any part deemed to have been duly modified for the load actually connected at the time of expiry of the said period of six months and I/we further agree to submit fresh A & A form for the same.

*[Handwritten Signature]*

Applicant

*[Handwritten Signature]*

नि० (का०)  
वि० वि० नि० लि०, मेरठ

*[Handwritten Signature]*

आर० ए० सी० डी० ए० १५५५

*[Handwritten Signature]*




## AFFIDAVIT

I/we hereby agree that the Uttar Haryana Bijli Vitran Nigam Limited shall have the right to restrict the hours of supply to my/our installation as required and power supply to may be suspended on the account.

I/we hereby agree that the power regulatory measures as notified by the Nigam from time to time.

I/We further undertake that i/we shall not lodge any claim with the Nigam from the period the power supply is recestriected/suspended/disconnected due to above reasons.

  
Executive Engineer  
Signature of Applicant  
Electricity Distribution Division  
Saharanpur

  
नि० (वा०)  
५०वि०वि०नि०लि०, मेरठ

ACCEPTED

12/12/2012

**AFFIDAVIT**

I, Excuse EPO (one) v. Dilley Tyms

do hereby solemnly affirm and declare as  
under:

1. That I have applied for power connection from U.H.B.V.N Ltd, Yamuna Nagar.
2. That I will install the \_\_\_\_\_  
At \_\_\_\_\_
3. That by the said process no air or water pollution will be discharge.
4. That I have no objection if my electric connection is disconnected under Pollution Act.

**Verification:-**

Verified that the contents of the above said affidavit are true and correct to the best of my knowledge and belief and nothing has been concealed therein.

Verified at Jagadhri

On \_\_\_\_\_

  
DEPONENT

Electricity Division-1

Verified at Jagadhri


On \_\_\_\_\_

  
Electricity Division-1

Sub-Inspector

DEPONENT

DEPONENT

  
नि० (वा०)  
प०वि०वि०नि०लि०. मेरठ

  
AEE OF GOVT. MEERUT



POWER FACTOR

The power factor at any point of industrial/agriculture supply must be less than 35 percent and in the event of the said power factor being found to be less than 35 percent the consumer shall be liable to have his installation of disconnected from the system's supply system until the power factor has been brought up to 45 percent by methods approved.

Without prejudice to clause the divisional officer concerned may a notice of three months of my industrial/agriculture consumer asking him to install the necessary requirements (capacitors) for improving and maintaining the date of notice and in case with the consumer concerned fails to install such equipment in the above period of notice and division officer may install such defaulting equipment and charged rental at rate as prescribed in the scheduled general charges of the board.

Signature of the consumer.

Executive Engineer

Electricity Distribution Division-I

Seharanpur

Attested

Vijay Kumar Sharma (Gautam)

Ch. No. 26278, Dist. Court Jagadhri,

Yamuna Nagar (Haryana)


नि० (वा०)  
पावि०वि०नि०लि०, मेरठ

YNR

**AFFIDAVIT**

I \_\_\_\_\_ S/o Shri \_\_\_\_\_  
 R/o Executive 300 (1) V- Dikky Tapan  
 do hereby solemnly affirm and declare as under :-


- (1) That I have applied for Temp/R.C.O./Domestic/NDS/Power Connection/Change of name /Ext./Reduction of load with U.H.B.V.N.
- (2) That I shall abide by the rules and regulations amended from time to time by U.H.B.V.N.
- (3) That I am not a defaulter of U.H.B.V.N. If any state I found defaulter of U.H.B.V.N. I shall fully responsible to pay all the charges/Dues outstanding with U.H.B.V.N. for my above said connection.
- (4) That at present my age is \_\_\_\_\_ years.
- (5) That it is certified that I shall pay the arrears of defaulting amount if any, pertaining to the premises in which electricity connection is applied by me.

  
**Deponent,**  
 Executive Engineer  
 Electricity Distribution Division-I  
 Sub-division

**Verification :**

Verified that all the contents of the above said affidavit are true and correct to the best of my knowledge and belief and nothing has been concealed there in.

Verified at \_\_\_\_\_ on Dated \_\_\_\_\_ 20\_\_\_\_

  
 नि० (वा०)  
 पाठिकादि० नि० लि०, मेरठ

AEE 'OP' S/DIV No.1 YNR


  
**Deponent,**  
 Executive Engineer  
 Electricity Distribution Division-I  
 Sub-division



AFFIDAVIT

I, Executive CDD-(C) V. Dikshitar do here by solemnly affirm and declare as under:


- 1. That the deponent is sole proprietor.
- 2. That the firm have applied for a power electric connection from U.H.B.V.N. Ltd., Yamuna Nagar.
- 3. That my \_\_\_\_\_ is situated village \_\_\_\_\_ Distt Yamuna Nagar.
- 4. That I have no objection if my electric connection is disconnected under P.W.D, B&R Act.


  
**DEPONENT**  
 Executive Engineer  
 Electricity Distribution Division-1  
 Saharanpur

Verification:-

Verified that the contents of the above said affidavit are true and correct to the best of my knowledge and belief and nothing has been concealed their in.

Verified at Jagadhri  
On \_\_\_\_\_

  
**DEPONENT**  
 Executive Engineer  
 Electricity Distribution Division-1  
 Saharanpur

  
 नि० (वा०)  
 प०वि०वि०नि०लि०, मेरठ

AFFIDAVIT No. 1 YNR

दूरभाष 0121-2665734  
फैक्स 0121-2666062



कार्यालय  
Office of the  
प्रबन्ध निदेशक  
MANAGING DIRECTOR  
पश्चिमांचल विद्युत वितरण निगम लि०  
Paschimanchal Vidyut Vitran Nigam Ltd.  
विक्टोरिया पार्क, मेरठ  
Victoria Park, MEERUT—250001  
CIN-U31200UP2003SGC027458

ISO9001:2015

पत्रांक सी-600 / नि० / वा० / प.वि.वि.नि.लि. /

दिनांक:- 27 मार्च, 2017

कार्यालय ज्ञाप

एतद्वारा निगम कार्यहित में अधिशासी अभियन्ता, विद्युत वितरण खण्ड-प्रथम, सहारनपुर का आदेशित किया जाता है कि ग्राम ढिक्का टापरी, जनपद सहारनपुर (उ०प्र०) को दिये गये 600 किलोवाट स्वीकृत भार के संयोजन को 400 किलोवाट घटाकर 200 किलोवाट करने हेतु हरियाणा विद्युत निगम का आदेशित कर दे, जिससे 400 किलोवाट के फिक्स चार्ज जो ₹० 100 प्रति किलोवाट है तथा ढिक्का टपरी में आपूर्तित ऊर्जा का हरियाणा विद्युत निगम द्वारा निर्गत विद्युत बिल का भुगतान हेतु इस शर्त के साथ खण्ड का राजस्व वसूली के मद से भुगतान हेतु अधीकृत किया जाता है कि हरियाणा विद्युत निगम के निर्गत बिल से अधिक अथवा बराबर राजस्व वसूली करेंगे।

(संजय आनन्द जैन)

मुख्य अभियन्ता (वाणिज्य)

दिनांक:- 27, मार्च, 2017

पत्रांक सी-600 / नि० / वा० / प.वि.वि.नि.लि. /

प्रतिलिपि:- निम्नलिखित को सूचनार्थ प्रेषित।

1. प्रबन्ध निदेशक, प०वि०वि०नि०लि०, मेरठ।
2. निदेशक (तकनीकी / वाणिज्य / वित्त), पविनि.लि., मेरठ।
3. मुख्य अभियन्ता (वितरण), सहारनपुर क्षेत्र, सहारनपुर।
4. अधिशासी अभियन्ता, विद्युत वितरण खण्ड-प्रथम, सहारनपुर।

(संजय आनन्द जैन)

मुख्य अभियन्ता (वाणिज्य)

नि० (वा०)  
प०वि०वि०नि०लि०, मेरठ