

Validate

Print

Help

**Item Rate BoQ**

Tender Inviting Authority: SUPERINTENDING ENGINEER ELECTRICITY DISTRIBUTION CIRCLE-I, SAHARANPUR

**Name of Work:** विद्युत वितरण खण्ड-बेहट के अन्तर्गत मौहल्ला महाजनान फीडर पर क्षतिग्रस्त ए०वी०सी० केबिल बदलने व एल०टी० केबिल बॉक्स बदलने का कार्य, मण्डी रोड, पेपर, मो० खालसा एवं टेली फोन एक्सचेंज के पास 63 के०वी०ए० के परिवर्तक बदलने का कार्य, ग्राम कादरपुर मे 250 के०वी०ए० परिवर्तक की एल०टी० रोड बदलने, पेकिंग और टेप चेंजर की रिपेयरिंग का कार्य, रायपुर-द्वितीय पर एक न० क्षतिग्रस्त इन्कमिंग वी०सी०बी० बदलने का कार्य व बैटरी और बैटरी चार्जर लगाने का कार्य व पुराना स्टोर में जमा करने का कार्य एवं धाने के पास, मण्डी रोड व कन्नौस्तान के पास अर्थिंग का कार्य, खुसहालीपुर मे बैटरी व बैटरी चार्जर बदलने का कार्य, तहसील बेहट व बेहट देहात उपकेन्द्र पर 33 के०वी० ब्रेकर की रिपेयरिंग व कॉइल बदलने का कार्य।

S.T.E-Tender No: 37/W/EDC-I/SRE/2025-26

Name of the Bidder/ Bidding Firm / Company :						
PRICE SCHEDULE						
(This BOQ template must not be modified/replaced by the bidder and the same should be uploaded after filling the relevant columns, else the bidder is liable to be rejected for this tender. Bidders are allowed to enter the Bidder Name and Values only ) GST as applicable shall be paid extra.						
NUMBER #	TEXT #	NUMBER #	TEXT #	NUMBER #	NUMBER #	TEXT #
Sl. No.	Item Description	Quantity	Units	BASIC RATE In Figures To be entered by the Bidder without GST Rs. P	TOTAL AMOUNT Without GST in Rs. P	TOTAL AMOUNT In Words
1	2	3	4	5	6	7
1	Detail of Work					
1.01	Repairing of 33 KV Breacker and Replacement of Damage coil.	2	Job		0.00	INR Zero Only
1.02	Safely carriage of LT ABC Cable size 3x120 sq. from ESC SRE to site of work including loading and unloading at both ends.	350	Mtr		0.00	INR Zero Only
1.03	Laying, lifting, Stringing, proper sagging ABC cable of size 3x120+1x95+1x16 sq.mm. including fixing of all accessories.	350	Mtr		0.00	INR Zero Only
1.04	Removal of old and damage ABC cable from site of work to ESC SRE including loading and unloading at both ends.	280	Kg		0.00	INR Zero Only
1.05	Removal of 63 KVA T/F from the existing D/P after opening HT & LT connection and with shifting the T/F from the site to ESC, SRE/JE store with loading & unloading at both ends.	3	No		0.00	INR Zero Only
1.06	Safe cartage of 63 KVA T/F from ESC,SRE, to the site of work including loading & unloading at both ends. (Dist. Upto 40 km.)	3	No		0.00	INR Zero Only
1.07	Safe installation of 63KVA T/F on the double pole with complete fittings including making connections and commissioning.	3	No		0.00	INR Zero Only
1.08	Providing and fixing of LT Road of 250 KVA T/F in Village Kadarpara.	1	No		0.00	INR Zero Only
1.09	Repairing of packing and Tap Changer of 250 KVA T/f in Village Kadarpara.	1	Job		0.00	INR Zero Only
1.1	Safely carriage of 11 KV VCB (1 No) from ESC SRE to Site of work including loading and unloading at both ends.	1	No		0.00	INR Zero Only
1.11	Safely installation of 11 KV VCB connection properly.	1	No		0.00	INR Zero Only

1.12	Removal of Damage 11 KV VCB from site of work to ESC SRE including loading and unloading at both ends.	1	No		0.00	INR Zero Only
1.13	Safely Carriage of 24 Volt Battery Set and Battery Charger from ESC SRE to Site of work including Loading and unloading at both ends.	2	No		0.00	INR Zero Only
1.14	Safely Installation of 24 Volt Battery Set and Battery Charger properly.	2	No		0.00	INR Zero Only
1.15	Safely removal of damage Battery Charger & 24 Volt Battery Set from site of work to ESC SRE including loading and unloading at both ends.	2	No		0.00	INR Zero Only
1.16	water level Earthing of 03 No 400 KV T/F (1 No body & 1 No. neutral earthing) by boring of till water level minimum 60 Ft deep & fixing of G.I pipe 1 1/2" Dia (Jindal Class B) and connecting with G.I. Strip of size 50x6 mm and copper strip at bottom of G.I pipe to the T/F providing of required charcoal & salt in the pipe	6	No		0.00	INR Zero Only
<b>Total in Figures</b>					<b>0.00</b>	Zero Only
<b>Quoted Rate in Words</b>		<b>INR Zero Only</b>				